

Electric Construction System Hardening (SRIP 6)

Clarifying Questions and Responses #4

April 7, 2026

This Clarifying Questions and Responses #4 consists of 1 page (all 8.5" x 11").

It is the responsibility of the proposer to assure and guarantee that the proposer has received the Response in its entirety and that the Bidder accepts all conditions contained herein.

Question 1.1

Question in response to: Clarifying Questions and Responses #2 dated April 1, 2026, which states the following under **Response 1.1**:

“Yes.”

This response appears to confirm that, for this project, the **Prime Contractor may hold the A-General Engineering license**, while the **subcontractor performing the overhead and/or conductor-related work may hold the C-10 Electrical license**.

To confirm our understanding, would the District also accept the reverse arrangement, where the **Prime Contractor holds the C-10 Electrical license** and the **subcontractor holds the A-General Engineering license**?

Response 1.1

The District will accept either licensing structure. Provided that the Prime Contractor and Subcontractor collectively hold both an A-General Engineering license and a C-10 Electrical license, the licensing requirements for this project will be considered satisfied.

Question 1.2

How far off the pole line is the gas line on Glenshire Dr.? Markers were visible when fielding but looking to see if the utility knows more exact locations.

Response 1.2

It is the Contractor's responsibility to identify and verify the location of all existing underground facilities, including gas lines, in accordance with 811 requirements and applicable laws. The District does not guarantee the accuracy or completeness of field markings or facility locations. The Contractor shall coordinate with the appropriate utility owners and utilize the 811 service to ensure all facilities are properly located prior to construction.