

# Martis Valley Substation Modernization 2026

## Clarifying Responses #1

April 10, 2026

This Clarifying Response No. 1 consists of 1 page (8.5" x 11"). It is the responsibility of the proposer to assure and guarantee that the proposer has received the response in its entirety, and that they accept all condition contained herein.

The following question responses, clarifications and/or modifications shall be incorporated, as appropriate, into Drawings and Specifications for the above-referenced project and shall become part of the Bid Document (Contract) package.

### Question 1.1

Is there an engineer's estimate?

### Response 1.1

An engineer's estimate has not been prepared for this project.

### Question 1.2

Has the 145 kV vacuum circuit breaker already been procured?

### Response 1.2

Yes, the 145 kV vacuum circuit breaker has already been procured and is being stored onsite.

### Question 1.3

In Bid Section 00100, under Section 10, Part A, Subsection 6, does the comma between A-General Engineering and C-10 Electrical indicate that both licenses are required for the prime contractor, or that either license would be acceptable depending on the bidder's scope and approach?

### Response 1.3

Provided that the Prime Contractor and Subcontractor collectively hold both an A-General Engineering licence and a C-10 Electrical license, the licensing requirements for this project will be considered satisfied.

### Question 1.4

Is there a minimum portion of the work that must be self-performed by the prime contractor?

### Response 1.4

Bidders shall not subcontract greater than 50% of this project's work, as determined by the values submitted on the Subcontractor form and on the bid schedule for the work that the subcontractor is responsible for.