

Electric Construction System Hardening (SRIP 6) 2026

ADDENDUM NO. 1

This ADDENDUM NO. 1 consists of 2 pages (1 - 8.5" x 11"). It is the responsibility of the proposer to assure and guarantee that the proposer has received the response in its entirety, and that they accept all conditions contained herein.

1. Incorrect: Section 00310 – Measure and Payment, Part 2, 4, 5, and 6. On Page 26

4. Bulk Bag (~25CF) Base Rock

A. One bag of Base Rock per pole hole location

5. Corrugated ADS N-12 30" x 6'8"

A. Install one 30" x 6'8" section in each excavated pole hole and backfill and compact outer section of pipe

6. All excavations must be covered

A. Cover all open holes with 3/4" 4' x 4' plywood

Correct: Contractor is to provide

4. Bulk Bag (~25CF) Base Rock

A. One bag of Base Rock per pole hole location

5. Corrugated ADS N-12 30" x 6'8"

A. Install one 30" x 6'8" section in each excavated pole hole and backfill and compact outer section of pipe

6. All excavations must be covered

A. Cover all open holes with 3/4" 4' x 4' plywood

2. Incorrect: Section 00100 Instruction to Bidders Page 9

6. The appropriate contractors' license for the Work to be performed (P.C.C.§3300), which the DISTRICT has determined to include: A-General Engineering.

Correct:

6. The appropriate contractors' license for the Work to be performed (P.C.C.§3300), which the DISTRICT has determined to include: A-General Engineering, C10 Electrical, and C61/D31 Poles Installation and Maintenance

Electric Construction System Hardening (SRIP 6) 2026

ADDENDUM NO. 1

This ADDENDUM NO. 1 consists of 2 pages (1 - 8.5" x 11"). It is the responsibility of the proposer to assure and guarantee that the proposer has received the response in its entirety, and that they accept all conditions contained herein.

3. Incorrect: Section 00100 Instruction to Bidders Page 10

Correct: Add 9 and 10.

9. Bidders shall have a minimum of five (5) years of experience in the Powerline construction or rebuild of electrical distribution facilities of similar or greater size.

A. Bidders shall document at least five (5) projects in the past five (5) years in which they were the primary contractor in the Powerline construction or rebuild of electrical distribution facilities. Include this information in the Experience Statement in Section 00300 – Bid Forms.

B. Bidders shall provide a reference for each of the projects. Include name, position, email and phone number. Include this information in the Experience Statement in Section 00300 – Bid Forms.

10. Bidders shall not subcontract greater than 60% of this project's work, as determined by the values submitted on the Subcontractor form and the values submitted on the bid schedule for the work that the subcontractor is responsible for.