



INSTALLATION NOTES:

1. DOOR SHALL OPEN A MINIMUM OF 90 DEGREES.
2. WORKING SPACE SHALL COMPLY WITH REQUIREMENTS IN CONSTRUCTION STANDARD M-1.2
3. CLEARANCE REQUIREMENTS (ALL CLEARANCES SHALL BE MET SIMULTANEOUSLY):
 - "A" - 10" MINIMUM
 - "B" - 5" MINIMUM
 - "C" - 6" MINIMUM TO 9" MAXIMUM DEPTH FROM FRONT OF PANEL TO FACE OF FRAMING

M-1B.DWG



ELECTRIC DEPARTMENT

Metering

Recessed Residential Meter Enclosures

Drawn	Design	Approved	Date	Category	Voltage	M-1B
SMS	SMS	JAH	4/4/18	Metering	Secondary	